



MAMCO ENTERPRISES

Mumbai – 400104, E mail – suresh@mamcogroup.in

Web : www.mamcogroup.in

PROUD TO BE INDIAN

Report No: GCI/V/LAB/EM-G0175/16-SP/16-17/Sep-00/ 0595

Date: 29/09/2016

ANALYSIS REPORT (For the Month of September-16)

Client Details		Sample Details	
Name	M/s. MAMCO ENTERPRISES	Sample Code	GCI /V/16/I5/VOC/S1
Address	Goregaon (W), Mumbai -400104	Location	VOC Filter Carbon Coated – Black
		Date of analysis	27/09/2016
		Sampling Instrument	VOC Meter
Analysis Done By	Mr. Raghav Soni	Sampling Method	Instrument Manual

WORK PLACE ANALYSIS RESULTS

Sr. No.	Parameters	Unit	Results Before Filter	Results After Filter	efficiency	Reference Method
1.	Methane	ppm	3521.9	0.2	99.99%	Online VOC Analyzer
2.	Ammonia	ppm	2853.3	0.1	99.99%	Online VOC Analyzer
3.	TVOC	ppm	1254.3	0.1	99.99%	Online VOC Analyzer

VOC Filter of M/s. Mamco Enterprises labelled as VOC Filter Carbon Coated has shown 99.99% efficiency towards TVOC , Methane & Ammonia.

Authorized Signatory

- Analysis is subject to the condition In Which the Sample Is received at our Laboratory.
- Reports can not be used as an evidence anywhere including judiciary purpose without our prior permission.
- Sample will be retained fill one month from the date of sampling.